

Laboratory: „F Plus“ OOD, ul. „Vitosha“, 2042 Kostenets, Sofiiska oblast  
Office: bul. „Al.Stamboliyski“ 205, sgrada B, floor 3, off. 306B, Sofia 1000  
Telephone: +359 878 112 112; e-mail: office@fplus-eu.com; www.fplus-eu.com

Out № 620  
from 21.07.2023

**To  
The representatives of Alban  
Giacomo Spa**

On 16.12.2022 a fire resistance test was conducted on the doorset "Halspan 44 mm Prima". The fire impact was on the side of the hinges. Test duration was 70 minutes.

The thermal insulation criteria were fulfilled for 69 minutes, integrity was maintained for 70 minutes.

Halspan 44 mm Prima is a hinged door made from timber and derived timber products, classified EI1; EI260. The dimensions of the door leaves were (W x H) 2156 mm x 871 mm with an overall thickness of the door leaf of 56 mm.

The suitability of "Eclipse 2.1" (E302009234), produced by the company Alban Giacomo spa – Italy for installation in this door construction has been successfully verified by the fire resistance test as per EN 1634-1 for a test duration of 60 minutes.

For further details refer to the test report TR-391-01/29.05.2023 issued by F Plus Ltd.

The Halspan 44 mm Prima door, produced by the company YIANNAKIS KOKKINOS LTD. Has been successfully verified by the fire resistance test as per EN 1634-1;2014+A1:2018 for test duration of 70 minutes.

With respect,  
Head of Laboratory  
"Fplus" fire tests:

.....  
/Assoc. Proff. Eng. Detelin Spassov, PhD/

21.07.2023